

The Sample was not Collected
by this Laboratory

Not Valid for water
quality Legal Cases

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, RAJASTHAN, JAIPUR

REPORT OF THE CHEMICAL EXAMINATION OF WATER

Report No.: Raj/DW(Chem)/2025-26/ 1145-46

Dated: 17.6.25


Issued To,

Principal
Care International School, Balaji Vihar, Hathoj
Jaipur

District: Jaipur
Block/City: Hathoj

Ref_ID :	9	Lab Sample No. :	12
Reference : Your Letter No.:	-	Source :	Tank
Reference Dated :	09-06-2025	Source Location :	School Campus, Care International School, Balaji
Date of Receipt :	09-06-2025	Habitation/Ward No. :	Hathoj
Name of Sample Taker :	Banwari Lal Jat	Village/Colony/Town :	Hathoj
Desig. of Sample Taker :	-	Gram Panchayat/City Area :	Hathoj
Latitude :		Date of Collection :	09-06-2025
Longitude :		Date of Examination :	16-06-2025
Elevation in Meter :			
Test Parameters	IS-10500:2012		Test Values of Samples
	Requirement (Acceptable Limit)	Permissible limit in the absence of alternative sources	
1 pH	6.5 to 8.5	No Relaxation	7.9
2 Turbidity(NTU)	1	5	Clear
3 Colour (Hazen Unit)	5	15	None
4 Odour	Unobjectionable	-	UO
5 Total Alkalinity (as CaCO ₃)	200	600	190
6 Total Hardness (as CaCO ₃)	300	600	100
7 Calcium (as Ca ⁺⁺)	75	200	12
8 Magnesium (as Mg ⁺⁺)	30	100	17
9 Chloride (as Cl ⁻)	600	1000	50
10 Sulphate (as SO ₄ ⁻²)	200	400	8
11 Nitrates (as NO ₃ ⁻)	45	No Relaxation	13
12 Fluoride (as F ⁻)	1.0	1.50	0.39
13 Total Dissolved Solids	500	2000	497
14 Residual Chlorine	0.2	0.5	Nil

Note:- Report is not valid for Food Licence or any Certificate.


Superintending Chemist
PHED, Lab, Jaipur
Dated:

Report No.: Raj/DW(Chem)/2025-26/
Copy to:

1. The Chief Chemist, Public Health Engineering Department, Rajasthan, Jaipur.

0

Superintending Chemist